



Certificate number: 2111743 (1)

Issued 30/11/2021

Expires 30/11/2026

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Seetru Limited.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> to ensure that the certificate is still valid.

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
Seetru Limited
Albion Dockside Works
Bristol
BS1 6UT



Product Certificate

Appendix to Certificate number: 2111743

The following products belong to this certificate

PRODUCT DESCRIPTION Range of bronze bodied pre-set pressure relief valves (available between 0.2-16 bar on each model) incorporate a manually operated easing gear with brass seat and PTFE or EPDM washers. ATS3 – Without Production Surveillance.
MODEL(S) LGS DN15 - ½"; LGS DN20 - ¾"; LGS DN25 - 1"; LGS DN32 - 1 ¼"; LGS DN40 - 1 ½"; LGS DN50 - 2".
SIZE: See model.
SCOPE: Manufacturer recommended maximum working pressure 16 Bar & maximum operating temperature 85°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C. Above ground use only.
MARKING Seetru, date of manufacture (MM/YY), set pressure, model number etched on body. Flow arrow mould on body. CR located in inlet.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES N/A.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements. The fitting is to be so installed as to be readily accessible for examination, test, maintenance, replacement, or operation.

Extra Notes